eurofins | Built Environment Testing

Report for:

Pure Maintenance of Santa Barbara County 5511 Ekwill St
Suite D
Santa Barbara, CA 93111

Regarding: Eurofins EPK Built Environment Testing, LLC
Project: ML
EML ID: 3151265

Approved by:



Technical Manager
Murali Putty

Dates of Analysis:
MoldReport Culturable air fungi (Incl. Asp spp.): 02-09-2023

Service SOPs: MoldReport Culturable air fungi (Incl. Asp spp.) (EM-MY-S-1043)
AIHA-LAP, LLC accredited service, Lab ID #102856

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. Due to the nature of the analyses performed, field blank correction of results is not applied. The results relate only to the samples as received and tested. Information supplied by the client which can affect the validity of results: sample air volume.

Eurofins EPK Built Environment Testing, LLC ("the Company"), a member of the Eurofins Built Environment Testing group of companies, shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.
Eurofins EPK Built Environment Testing, LLC's LabServe® reporting system includes automated fail-safes to ensure that all AIHA-LAP, LLC quality requirements are met and notifications are added to reports when any quality steps remain pending.

Eurofins EPK Built Environment Testing, LLC
111 Anza Boulevard, Suite 122, Burlingame, CA 94010
(866) 888-6653 www.eurofinsus.com/Built

Client: Pure Maintenance of Santa Barbara County
Re: ML

Date of Sampling: 01-26-2023
Date of Receipt: 01-31-2023
Date of Report: 02-09-2023

CULTURABLE AIR FUNGI REPORT

Location:	1: Hallway		2: Living Room/Dining	
Comments (see below)	None		None	
Lab ID-Version‡:	15238429-1		15238430-1	
Analysis Date:	02/09/2023		02/09/2023	
Medium:	MEA		MEA	
	raw ct.	cfu*/m3	raw ct.	cfu*/m3
Aspergillus niger				
Aspergillus ochraceus				
Aspergillus versicolor				
Aureobasidium				
Basidiomycetes				
Bipolaris/Drechslera group				
Botrytis				
Chaetomium				
Cladosporium				
Curvularia				
Epicoccum				
Fusarium				
Non-sporulating fungi				
Paecilomyces				
Penicillium				
Phoma				
Rhizopus				
Stachybotrys chartarum				
Ulocladium				
Yeasts				
Positive Hole	0		0	
Sample volume (liters)	75		75	
§ TOTAL CFU*/M3		< 13		< 13

* cfu = colony forming units Positive hole correction chart used for all calculations

Comments:

Note: Interpretation is left to the company and/or persons who conducted the field work. Variation is an inherent part of biological sampling. The presence or absence of a few genera in small numbers should not be considered abnormal.
NORMAL SPORE LEVELS: Indoor spore levels usually average 30 to 80% of the outdoor spore level at the time of sampling, with the same general distribution of spore types. Filtered air, air-conditioned air, or air remote from outside sources may average 5 to 15% of the outside air at the time of sampling. (These percentages are guidelines, only. A major factor is the accessibility of outdoor air. A residence with open doors and windows and heavy foot traffic may average 95% of the outdoor level while high rise office buildings with little air exchange may average 2%. Dusty interiors may exceed 100% of the outdoors to some degree, but will still mirror the outdoor distribution of spore types.)
PROBLEM INTERIORS: A substantial increase of one or two spore types which are inconsistent with and non-reflective of the outside distribution of spore types is usually indicative of an indoor reservoir of mold growth.

The limit of detection is 1 raw count per volume of air sampled. The analytical sensitivity is 1 raw count/volume x the positive hole correction factor.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".
§ Total CFU/m3 has been rounded to two significant figures to reflect analytical precision.
Fungal culture types listed without a count or data entry were not detected during the course of the analysis for the respective sample.